

NATURAL GAS PLUMBING REQUIREMENTS  
AND  
SOUTHERN BUILDING CODE

**\*\*NOTE\*\* Plumber must be licensed in the State of Alabama. \*\*NOTE\*\***

NO BUSHING REDUCERS

NO UNIONS, EXCEPT AFTER CUT-OFF VALVE AT EACH APPLIANCE

NO COPPER TUBING EXCEPT SHORT PIECE AFTER CUT-OFF VALVE

USE GALVANIZE, BLACK IRON, or APPROVED CORRUGATED STAINLESS STEEL  
PIPE

EACH APPLIANCE MUST HAVE AN ACCESSIBLE CUT-OFF VALVE

NEED A LETTER FROM PLUMBER THAT INCLUDES:

1. STATEMENT THAT IT WAS PLUMBED ACCORDING TO SOUTHERN BUILDING CODE;
2. PRESSURE TEST RESULTS - (PRESSURE TEST ON PLUMBING WHICH SHALL BE NOT LESS THAN 20 PSI, HELD FOR A MINIMUM OF 30 MINUTES).
3. COPY OF ALABAMA PLUMBER'S LICENSE

THIS MUST BE COMPLETED PRIOR TO SERVICE BEING ISSUED.

NOVEMBER 4, 2013  
MSM/BLM