

NATURAL GAS PLUMBING REQUIREMENTS  
AND  
SOUTHERN BUILDING CODE

NO BUSHING REDUCERS

NO UNIONS, EXCEPT AFTER CUT-OFF VALVE AT EACH APPLIANCE

NO COPPER TUBING EXCEPT SHORT PIECE AFTER CUT-OFF VALVE

USE GALVANIZE, BLACK IRON, or APPROVED CORRUGATED STAINLESS STEEL  
PIPE

EACH APPLIANCE MUST HAVE AN ACCESSIBLE CUT-OFF VALVE

NEED A LETTER FROM PLUMBER THAT INCLUDES:

1. STATEMENT THAT IT WAS PLUMBED ACCORDING TO SOUTHERN  
BUILDING CODE ;
2. PRESSURE TEST RESULTS - (PRESSURE TEST ON PLUMBING WHICH SHALL  
BE NOT LESS THAN 20 PSI, HELD FOR A MINIMUM OF 30 MINUTES).
3. COPY OF PLUMBERS LICENSE

THIS MUST BE COMPLETED PRIOR TO SERVICE BEING ISSUED.

November 9, 2011,  
MSM/BLM